

Quick Generator Checks

Monthly Checklist



Bridgeway

	Date _____ Initials _____	Date _____ Initials _____	Date _____ Initials _____	Date _____ Initials _____	Date _____ Initials _____	Date _____ Initials _____
Check for any faults and record						
Check oil level/leaks						
Check coolant level/leaks						
Check fuel level/leaks						
Record hour meter						
Check coolant heater						
Battery charger functional						
Record coolant temp, oil pressure, at end of exercise period						
Test panel lights						
Annunciator lamp test, if applicable						
Check battery electrolyte level and signs of excessive gassing, if applicable (Must be done with unit turned "off")						
Start generator exercise generator for 30 minutes with load						
Control switch is in AUTO						

Emergency Service - 800.969.3966